

BENSALEM TOWNSHIP FIRE MARSHAL'S OFFICE



AUTOMATIC SPRINKLER SYSTEM ANNUAL TEST REPORT

Only this document will be accepted by the Bensalem Township Fire Marshal's Office for annual testing purposes as required by the International Fire Code and applicable N.F.P.A. standards.

PROPERTY NAME _____ DATE OF INSPECTION ____/____/____

PROPERTY ADDRESS _____ INSPECTOR _____

TESTING AGENCY NAME _____

FIRE MARSHAL'S LICENSE # _____ PHONE # _____

TESTING AGENCY ADDRESS _____

1. TYPE OF SYSTEM: WET DRY PIPE PRE ACTION ANTI-FREEZE DELUGE
2. LOCATION OF MAIN SHUTOFF VALVE _____
3. NUMBER OF RISERS ON SYSTEM _____ ARE THEY PROPERLY IDENTIFIED? YES NO
4. SHUTOFF VALVE TYPE: O S & Y P.I.V. WALL INDICATOR
5. ANY SYSTEM MODIFICATIONS SINCE LAST INSPECTION? YES NO IF YES, EXPLAIN _____
6. SPRINKLER HEADS TYPE _____ MANUFACTURER _____ MODEL _____
TEMP RATING _____ YEAR MANUFACTURED _____
7. DATE OF LAST FLOW TEST ____/____/____ AVAIL FLOW _____ GPM
FIRE PUMP? YES NO TYPE: DIESEL ELECTRIC GASOLINE OTHER
JOCKEY PUMP? YES NO
8. DATE OF LAST FIRE PUMP TEST ____/____/____ GENERAL PUMP CONDITION _____
9. LOCATION OF F.D. CONNECTION _____ SIGN PROVIDED? YES NO N/A
F.D. CONNECTION TYPE: 2 1/2" N.S.T 5" STORZ
10. PRESSURE READING: STATIC _____ P.S.I. 2" FLOW _____ P.S.I.
INSPECTOR TEST VALVE _____ P.S.I.
11. DOES FIRE ALARM SYSTEM RESPOND TO WATER FLOW AND TAMPER SIGNALS? YES NO N/A
12. DATE OF LAST INTERNAL PIPE INSPECTION? ____/____/____ RESULTS? _____
13. ARE ALL SPRINKLER HEADS UNOBSTRUCTED, CORRECT, AND SERVICEABLE? YES NO
IF NO, EXPLAIN IN "NOTES" SECTION.
14. SUPERVISION OF VALVES: SEALED LOCKED TAMPER SWITCH WHEEL REMOVED
15. ARE ALL SPRINKLER VALVES IDENTIFIED WITH SIGNS? YES NO
16. IS BUILDING VALVE ROOM HEATED? YES NO
17. IF DRY PIPE SYSTEM, WAS DRY PIPE VALVE TRIPPED, CLEANED, RESET? YES NO
18. IS DRY SYSTEM SUPERVISED FOR LOW AIR PRESSURE? YES NO
19. ALL THREADS AND CONNECTIONS COMPATIBLE WITH BENSALEM FIRE DEPARTMENT EQUIPMENT?
 1 1/2" N.S.T. 2 1/2" N.S.T. 4 1/2" N.S.T. 5" STORZ

