



BENSALEM TOWNSHIP
Department Of Public Safety
FIRE RESCUE DEPARTMENT
2400 Byberry Road - Bensalem, Pa 19020
Phone: 215-633-3617 - Fax: 215-633-3662

Barbeques and Outdoor Cooking Devices

308.3.1 Open-flame cooking devices.

Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exceptions:

1. One- and two-family dwellings.
2. Where buildings and decks are protected by an automatic sprinkler system.

308.3.1.1 Liquefied-petroleum-gas-fueled cooking devices.

LP-gas burners having a LP-gas container with a water capacity greater than 2.5 pounds [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exception: One and two-family dwellings.